

Emergency Telephone System Board Of DuPage County Policy and Procedures



Policy #: 911- 005.6
Previous Policy(s): 4.2.2
Effective Date: April 10, 2018
Revised: November 9, 2022

DuPage Emergency Dispatch Interoperable Subscriber Unit System (DEDIRS) Use of Emergency Button

Purpose:

The purpose of this policy is to ensure compliance with State of Illinois STARCOM21 and DEDIRS requirements for use and access of DEDIRS talk groups for the purpose of interoperability for emergency communications by acknowledging industry standards for definitions, terminology

Additional Authority:

Public Act 100-002

50 ILCS 750 Emergency Telephone System Act

50 ILCS 751 Wireless Emergency Telephone Safety Act

83 Illinois Administrative Code Part 725

83 Illinois Administrative Code Part 1325.415(m)

OEX-003B-89 Amending Section 40-20 of the DuPage County Code Pertaining to the Emergency Telephone System Board

Goal:

It is the goal of the Emergency Telephone System Board of DuPage County (DuPage ETSB) to provide one seamless method of interoperable communication for use by agencies on DEDIRS for non-member agencies.

Scope:

This policy shall apply to all Public Safety Answering Points (PSAPs) within the DuPage ETSB 9-1-1 System, including all Telecommunicators and other employees of the PSAPs, user agencies or DuPage ETSB staff, contracted vendors or other authorized agents, DEDIRS users and agencies receiving approval to access DEDIRS talk groups.

I. Policy Statement

DuPage ETSB leases a portion of the Motorola Solutions, Inc. STARCOM21 network in Illinois as an integrated component of its emergency dispatch telephone system. The system permits communication between telecommunicators and the first responding personnel they dispatch in response to calls placed to 9-1-1 or managed through the authorized PSAPs. The system also permits personnel from public safety agencies throughout the County to communicate with each other during emergency joint response situations.

To achieve seamless interoperable communication, the establishment of standardized operating procedures and acceptable naming conventions are required to ensure that first responders can effectively operate subscriber units while on duty but especially during critical, active incidents when speed and accuracy are critical.

Emergency Telephone System Board Of DuPage County Policy and Procedures



As defined in Policy #: 911- 005.5, a "Talk group" is the term given to assigned groups on a trunked radio system. Unlike a conventional radio which assigns users a certain frequency, a trunk system takes a number of frequencies allocated to the system. The control channel then coordinates the system so talk groups can share these frequencies seamlessly. The purpose is to dramatically increase bandwidth.

Policy 911- 005.6 shall deal specifically with the use of the emergency button on the subscriber unit.

II. Emergency Button

DEDIRS utilizes two radio technologies, digital trunked and conventional simplex.

This procedure describes the function of and the appropriate use for the emergency button on DEDIRS portable radios. The objective is the proper use of the emergency button as well as a uniform course of action by both DuPage County PSAPs and all field personnel. It is important to note that the emergency button will operate on trunked talk groups, as well on conventional channels, although those conventional channels might not have the equipment in place to monitor this activity. It should be noted the operation of the radio may differ (even slightly) when the emergency button is activated in the STARCOM21 (trunked) mode and the conventional mode.

III. Trunked Talk Groups

The emergency button is used:

- To send an emergency notification when field personnel are in distress, or
- When the user is unable to transmit a verbal emergency message due to heavy radio traffic, during times when verbalization may jeopardize the members safety, or when vital urgent situations arise e.g. MAYDAY.

Pressing the Emergency Button on a STARCOM21 Talk group:

- Emergency button activation will display the 6 digit radio identification number, alias name (e.g. ADSN CHF 100, or ADP01) and the talk group name on the radio consoles.
- The affected user that activated his or her emergency button will have priority over any other radio transmitting on the same talk group.
- During this time, the radio speaker will remain active, meaning affiliated subscriber units will hear all the radio traffic.
- Specific functionality will be covered in training material provided to each agency's subject matter expert.

IV. Conventional Channels

The emergency button is used:

- To send an emergency notification when field personnel are in distress.

Pressing the Emergency Button on a conventional channel:

- Emergency button activation will display a 4 digit radio identification number and the frequency name on radio consoles that have that frequency. For example, a dispatch console may display

Emergency Telephone System Board Of DuPage County Policy and Procedures



an emergency for primary fire dispatch frequency, but not for fire ground red if that frequency is not monitored by the console.

- Once the affected user pushes the Push-to-talk (PTT), some radios (depending on the model) will be able to decode the emergency signal. They might be able to convert the 4 digit radio ID to an alias name if they have the current aliases programmed in their radio.
- The affected user that activated his or her emergency button will be competing with any other radio transmitting on the same channel.
- Specific functionality will be covered in training material provided to each agency's subject matter expert.

V. Actions to be taken upon receipt of an Emergency Button activation

- The assigned Telecommunicator for a monitored talk group or channel will transmit "William 1 (for instance), you have an E1," (or similar procedure that the PSAP has established). If the alarm is for a non-monitored talk group, any console Telecommunicator can pull up the alarm window and handle the alarm. The level of activity at the communications center will determine which Telecommunicator handles non-monitored talk group alarms.
- The Telecommunicator should hold the air and attempt to contact the affected user (Police officer, firefighter, or other user). If the user that has activated his/her alarm cannot be reached over the radio after two (2) attempts, the Telecommunicator shall immediately notify the Watch Commander/Shift Supervisor/Incident Commander, including the last known location or GPS data of last location. The Watch Commander/Shift Supervisor/Incident Commander shall make every effort to contact the affected person by any means necessary. This action shall be taken whether the user is believed to be on duty or not.
- When the PSAP is notified of emergency button activation from a radio belonging to one of their assigned units currently working with an outside PSAP, the home PSAP will immediately advise the outside PSAP of the emergency button activation. The outside PSAP will advise the home PSAP when the activation has been resolved.
- All units assigned to a channel which experience emergency button activation shall remain off the radio, except for emergency communications, until the activation is resolved. If an alternate frequency has been designated by agency policy, all non-affected units and PSAPs may be switched to the alternate frequency leaving the affected unit and PSAP on the original frequency.
- Once the affected user has been successfully contacted by the Telecommunicator, the affected user shall respond and include the word "**ACCIDENTAL**" in his or her response. If the affected user does not use the word "**ACCIDENTAL**," the Telecommunicator should assume that the emergency activation is valid and immediately alert the Watch Commander/Shift Supervisor/Incident Commander who will coordinate the response to the distress call. If the user provides a response which in any way indicates that the signal was "**ACCIDENTAL**," (without having to remember the specific phraseology), the Telecommunicator shall announce that the activation is accidental and clear the alarm from the console screen.

Emergency Telephone System Board Of DuPage County Policy and Procedures



- If the location of the affected user is not known, the Telecommunicator shall immediately announce the affected user's alarm activation and request that any information about his or her last activity or location be relayed to the PSAP. The Telecommunicator and Shift Supervisor will utilize all other electronic methods to locate this member's location including but not limited to, radio GPS data, in-car data or CAD data.
- Verification activities may vary from agency to agency, but after an activation, the supervisor or his or her designee should confer with the affected user to confirm that he or she is safe.
- All agencies should establish similar policies for field units operating on conventional and/or tactical channels which might not be monitored by dispatch. In these cases, the Watch Commander/ Shift Supervisor/Incident Commander is responsible for the activities that would have been handled by the PSAP.

VI. Resetting the Emergency Button Activation

After activation of the emergency button on the APX radio, the user must reset the button activation, which can be accomplished on one of two ways:

- a. The operator can push and hold the orange emergency button for approximately 3 seconds; he or she will hear a tone and the emergency button will reset or
- b. Turn off the radio, wait approximately 3 seconds and turn the radio back on; this will reset the radio.

Policy adopted: November 9, 2022


Greg Schwarze, Chairman

Emergency Telephone System Board Of DuPage County Policy and Procedures



Policy #: 911- 005.6: Emergency Button Activation and Reset

As the senior officer/department for my agency, I hereby acknowledge that the DEDIRS users under my command and/or authority have received and been trained on DuPage ETSB Policy #911-005.6: Emergency Button Activation and Reset.

In addition, going forward, this agency will:

1. On an annual basis review and train on DuPage ETSB Policy #911-005.6: Emergency Button Activation and Reset.
2. Provide a copy of this form annually when training of subscriber users has been complete, including a roster of users using ETSB911@dupageco.org the main DuPage ETSB email.

I understand that the conditions set forth above have been implemented to ensure first responder safety and DEDIRS standardization.

Acknowledged and agreed to this _____ day of _____, 20____

Signature: _____

Printed Name and Title: _____

Agency: _____

Date Training was completed: _____

[] Subscriber Unit or PSAP Roster Attached